

Big Mesa Water Report

Month	Billed Gallons	HAA5*	TTHM*	Microbiological Sample
Aug-23	1,413,994	5.65	48	Absent
Sep-23	1,226,716	3.51	50.4	Absent
Oct-23	773,538	3.51	50.4	Absent
Nov-23	441,620	7.67	54	Absent
Dec-23	368,350	42.5	87.3	Absent
Jan-24	466,250	42.5	87.3	Absent
Feb-24	638,348	12.6	94.8	Absent
Mar-24	461,179	27.5	119	Absent
Apr-24	761,635	27.5	119	Absent
May-24	1,244,068	8.45	51.2	Absent
Jun-24	1,286,388	3.38	39.4	Absent
Jul-24	1,346,327	3.38	39.4	Absent
Aug-24	1,643,933	7.42	60.4	Absent
Aug-24	1,186,243	7.42	60.4	Absent

*Note: maximum contaminant level (MCL) for both Haloacetic Acids (HAA5) and Total Trihalomethanes (TTHM) is 60 and 80, respectfully. These tests are performed quarterly.